STANDARD OF PERFORMANCE COMPLIANCE REPORT QUARTER: APRIL 24 TO JUNE 24

PREPARED BY: "Torrent Power Limited, Dahej License Area"

SUBMITTED TO: GUJARAT ELECTRICITY REGULATORY COMMISSION

Year: 2024-25

Performa SoP 001: Fatal and Non-fatal accident report

Number of accidents for the quarter										
Name of Avac/Civals	Number of Accident in the Quarter				Cummulative since the first quarter of the current FY					
Name of Area/Circle	Depart	mental	Out side		Departmental		Outside			
	FH	NFH	FH	FA	NFH	FH	NFH	FH	FA	NFH
Dahej Licence Area	-	-	-	-	•	-	-	-	•	•
Total	-	-		-		-	-	-	•	-

FH-Fatal human, NFH-Non fatal human, FA-Fatal Animal

TORRENT POWER LTD Quarter : Q1- April -June Year : 2024-25

Performa SoP 003B: Register For Compiling The Complaints - Classification wise

	Classification	Pending complaints of previous quarter	Complaints received during the quarter	Total Complaints	Within stipulated time	Beyond Stipulated time	Total	Balance complaints to be redressed
Dahej Li	cence Area							
	Interruption in power supply- Loose	2	3	4=2+3	5	6	7=5+6	8 = (7-4)
A(i)	connections at meter, MCB or Service line or from pole	-	-	-	-	-	-	-
A(ii)	Interruption in power supply- Interruption due to line breakdown	-	-	-	-	-	-	-
A(iii)	Interruption in power supply- No Power complaint on account of blowing of HT/Drop Out (DO)/LT fuse	-	2	2	2	-	2	-
A(iV)	Interruption in power supply- Interruption due to failure of transformer or distribution transformer MCB	-	-	-	-	-	-	-
A(V)	Interruption in power supply- Load Shedding/schedule outages	-	-	-	-	-	-	-
B(i)	Quality of Power Supply-Ordinary case, which is requires no augmentation	-	-		-	-	-	-
B(ii)	Quality of Power Supply- Where Augmentation is required	-	-	-	-	-	-	-
B(iii)	Quality of Power Supply- Harmonics related issue		-	-	-	-	-	-
B(iV)	Quality of Power Supply- Neutral Volatge related issue	-	-	-	-	-	-	-
B(V))	Quality of Power Supply- Voltage variations related issue	-	-	-	-	-		-
C(i)	Meters - Stopped/ Defective meters	-	-	-	-	-	-	-
C(ii)	Meters -Meter accuracy test (Fast/Slow)	-	-	-	-	-	-	-
C(iii)	Meters-Burnt Meter	-	-	-	-	-	-	-
C(iv)	Meters-Stolen Meter	-	-	-	-	-	-	-
C(v)	Meters-Biling on average basis for more than two bills	-	-	-	-	-	-	-
C(vi)	Meters-Meter boxes/metering system	-	-	-	-	-	-	-
D(i)	Overhead lines - Loose wires	-	-	-	-	-	-	-
D(ii)	Overhead lines - Inadequate ground clearance	-	•	-	-	-	-	-
E(i)	Bills - For current bills where no additional information is required	-	-	-	-	-	-	-
E(ii)	Bills - where additional information relating to correctness of reading etc. is required.	-	-	-	-	-	-	-
E(iii)	Bills-Final bill for vacation of premises/change of occupancy	-	-	-	-	-	-	-
E(iv)	Bills-Change of Tariff	-	-	-	-	-		-
F(i)	Service Connections - Where extension of LT line up to 150 Meters is required Service Connections - Where extension of LT	-	-	-	-	-	-	-
F(ii)	line of more than 150 Metre and/or augmentation of distribution transformer is required.	-	-	-	-	-	-	-
F(iii)	Service Connections - Where erection of new distribution transformer is required		-	-	-	-	-	-
F(iv)	Service Connections-Where erection of new HT line and distribution transformer is required and/or existing HT line network is required to be augmented	-	-	-	-	-	-	-
F(v)	Service Connections-Where EHT level line and/or Sub-station is required to be erected and/or augmented	-	-	-	-	-	-	-
F(vi)	Service Connections-Modification in connected load	-	-	-	-	-		-
F(vii)	Service Connections-Name Change/reconnection/change of category	-	-	-	-	-	-	-
F(viii)	Service Connections-In case connection is denied after payment against demand note	-	-	-	-	-	-	-
F(ix)	Service Connections-Transfer of connection	-	-	-	-	-	-	-
G	Request for reconnection/consumer wanting disconnection	-		-	-	-	-	-
н	Refund of amount due in regard to temporary connection	-	-	-	-	-	-	-
J	Street Light compliant Others	-	-	-	-	-	-	-
J	Others Total	-	2	2	2	-	2	

Year: 2024-25

Performa SoP 004: Publicity carried out while displaying the contact details of Consumers complaints centers

Sr. No. (1)	Actions or steps carried out by distribution licensee towards public awareness in the quarter (2)	Likely number of consumers influenced (3)	Details about media (4)	
Dahej Li	cence Area	. ,		
	Web Site			
	Bill Glossary			
	New Tariff			
	Consumption Calculator			
	Procedural Guidance			
	Payment Options			
	Contact details			
1	Call Center details and numbers		Web Site www.torrentpower.com &	
	Torrent Power Mobile Links concept and details	Consumers at large	portal	
	Form Downloads (important application forms)		portai	
	FAQ's			
	Consumer Charter			
	Online Bill Payment (how to pay and related forms)			
	Energy Conservation tips			
	Safety Tips			
	Electricity Supply Code (copy of the code)			
	Information Boards			
2	Grievance Redressal Options (Internal redressal committee/ Consumer			
	Redressal Forum), In the Interest of Consumers by GERC & Application	10 (At one office)	Information Board	
	Processing Charges			
3	Banners			
	Portal Connect information displayed at different locations	10	Displayed at Plot No. Z/21 office	
	Bills			
4	Front side :Portal Connect Information, Energy Saving Tips	137	Information about Call Centre Info,	
	Back side : Call Centre Info, Portal Connect Information, Redressal	137	Portal Connect Information, Energy	
	forum details, Tariff rate		Saving tips, Redressal forum details	
5	Email - Billing	137	Email	
6	Power Factor Awareness Programme			
	Personal Visit to HT, LTMD & LT Consumers	2 nos.	Consumer was guided for improvement of PF	

Year : 2024-25

Performa SoP 005: Failure of Distribution Transformer

	No. of existing Distribution Transformer at the start of the quarter /year		Total number of Distribution Transformers	Total Number of Distribution Transformers failed	% Failure rate of Distribution Transformer
	Α	В	C = A+B	D	E = (D) * 100/C
Dahej Licence Area	8	0	8	0	0.00%

Year: 2024-25

Performa SoP 006: Failure of Power Transformer

	No. of existing Power Transformer at the start of the quarter/year		Total number of Power Transformers	Total number of Power Transformers failed	% Failure rate of Power Transformer
	Α	В	C = A+B	D	E = (D) * 100/C
Dahej Licence Area	8	-	8	-	0.00%

Year :2024-25

Performa SoP 010: A System Average Interruption Frequency Index (SAIFI)

Sr. No.	Month	Number of Sustained Interruptions during the Reporting Period=Ai	Number of Interrupted Customers for Sustained Interruptions events during the Reporting Period =Ni	Total no of customers served for the Areas=Nt	Total Number of Interrupted Customers for Sustained Interruption events during the Reporting Period = ∑(Ai x Ni)	SAIFI=∑(Ai x Ni)/Nt
(1)	(2)	(3)	(4)	(5)	(6)=∑(3 x 4)	(7)=(6)/(5)
Dahej Lic	ence Area					
Α	Apr-24	0	0	130	0	-
В	May-24	1	7	131	7	0.053
С	June-24	0	0	137	0	-

Year: 2024-25

Performa SoP 011: System Average Interruption Duration Index (SAIDI)

Sr. No	Month	Number of Sustained Interruptions during the Reporting Period = Ai	I I IIITAMA	Restoration time for each Interruption Event = Ri	Number of Interrupted Customers for Sustained Interruption events during the Reporting Period = Ni	Total Customer Interruption Duration = Ri x Ni	Total Number of Customers Served for the Areas = Nt	Cumulative Customer Interruptions Duration = ∑ (Ri x Ni)	SAIDI = ∑ (Ri x Ni) / Nt
		Nos	Hr : Min	Hr : Min	Nos	Hr : Min	Nos	Hr : Min	Hr :Min
(1)	(2)	(3)	(4)	(5)=(4)/(3)	(6)	(7) = (5) * (6)	(8)	$(9) = \sum (5 \times 6)$	(10) = (9)/(8)
Dahej Lic	ence Area								
Α	Apr-24	-	-	-	-		130	-	-
В	May-24	1.00	00:06	00:06	7		131	00:42	00:00
С	June-24	-	-	-	-		137	-	-

Year: 2024-25

Performa SoP 012: Momemtary Average Interruption Frequency Index (MAIFI)

Sr. No.	Month	Total Number of Momentary interruptions Imi	Total no of customers affected due to Momentary Interruption Events during the Reporting Period =Nmi	Number of customer Momentary interruptions= Imi*Nmi	Total no of customers served=Nt	Cumulative Momentary Customer Interruptions =∑(Imi x Nmi)	MAIFI = ∑(Imi x Nmi)/ Nt			
(1)	(2)	(3)	(4)	(5) = (3) * (4)	(6)	(7) = Total of (5)	(8)= (7)/ (6)			
Dahej L	Dahej Licence Area									
Α	Apr-24	1	1	1	130	1	0.008			
В	May-24	-	-	-	131	-	-			
С	June-24	-	-	-	137	-	-			

Year : 2024-25

Performa SoP 013: Customer Average Interruption Duration Index (CAIDI)

Sr. No	Month	Total Number of Sustained Interruptions during the Reporting Period = ∑ Ai	Total Restoration time for Interruption Events = ∑Ri	Total Number of Interrupted Customers for Sustained Interruption events during the Reporting Period = ∑Ni	CAIDI=∑ (Ri x Ni) / ∑ (Ai x Ni) = SAIDI/ SAIFI
(1)	(2)	(3)	(4)	(5)	$(6)=(4 \times 5) / (3 \times 5)$
Dahej L	icence Area				
Α	Apr-24	-	-	-	-
В	May-24	1	6	7	00:00
С	June-24	-	-	-	-

Year: 2024-25

Performa SoP 015: Meter Faults

Consumer Category	No.of faulty meters at the start of the quarter / year (1)	No. of faulty meters added during the quarter / year (2)	Total no. of defective /faulty meter (3) = (2) + (1)	•	No. of faulty meters pending at the end of quarter (5) = (3)-(4)
Dahej Licence Are	a				
Single Phase	-	-	-	•	-
Three Phase	-	-	-	-	-

Torrent Power Limited Quarter : Q1- April -June Year : 2024-25

SoP 016: Compensation Details

		SoP 016: Comp				_	
		Compensation payable to consumer for	С	aimed	Payabl No. of cases in		
Sr. No. Dahej Li	Service Area	the period of default in case of violation of standard	No. of cases	Amount (Rs.)	No. of cases in which compensation is payable	Amount payable (Rs.)	Amount paid (Rs.)
1	Registration of complaint and intimation of Unique complaint Number to the Complainant	Rs. 50/- for each default					
2	Issuance of Demand Note for New Connection, Load Enhancement, Shifting of connection at other premises, Conversion of Service, Temporary Supply, Shifting of Service Connection in exiting premises, Deviation of line and Shifting of equipments	Rs. 50 for each day of default.					
3	New Connection, Load Enhancement, Shifting of connection at other premises and Conversion of Service where no Network erection and/or augmentation is required.	Rs. 50 for each day of default.					
4	New Connection, Load Enhancement, Shifting of connection at other premises and Conversion of Service where Network erection and/or augmentation is required.	Rs. 50 for each day of default.					
5	Release of temporary supply	Rs. 50 for each day of default.					
e	Shifting of meter/services in the						
6	existing premises	Rs. 50 for each day of default.					
7	Shifting of LT/HT lines						
8	Shifting of Transformer structures						
9	Settlement of amount for refunding of excess amount after completion of work.						
10	Transfer of Service Connection with respect to change of name or change of ownership	Rs. 50 for each day of default.					
11	Application from consumer requesting Change in Tariff Class/Category.	Rs. 50 for each day of default.					
12	Complaint Related to Billing	Rs. 50 for each day of default.					
13	Replacement of Meter	Rs. 25/- for each day of default subject to maximum of Rs. 1500/- for LT connections and Rs. 250/-for each day of default subject to maximum of Rs. 2500/- for HT connections.					
14	Reconnection of Supply	Rs. 25/- for each six hours (or part thereof) of delay in restoration of supply subject to maximum Rs. 500/- for LT connection and Rs. 50/- for each six hours (or part thereof) of delay in restoration of supply subject to maximum Rs. 1000/- for HT connection.			NIL		
15	More than 2 interruptions in a day to the consumer for the reasons not attributable to the nature of fault as mentioned in Clause 8.4 of these Regulations.	Rs. 25/- for each interruption subject to maximum Rs. 500/- for LT connection and Rs. 50/- for each interruption subject to maximum Rs. 1000/- for HT connection.					
16	Failure to restore power supply in case of blowing of fuse of LT side distribution transformer, at consumer premises, trouble of MCB of distribution transformer, loose connection at pole, MCB or meter, etc.	Rs. 50/- per hour per Consumer for the first					
17	Failure to restore power supply in case of blowing of HT side fuse of distribution transformer	two hours of default. Thereafter Rs. 100/- per hour per Consumer subject to maximum of Rs. 500/- per day for LT					
18	Failure to restore power supply in	consumer and maximum of Rs. 2000/- per					
19	case of HT and LT line fault Failure to restore power supply in case of Distribution transformer failure	day for HT consumer.					
20	Failure to restore power supply in case of failure of underground service or underground HT/LT cable						
21	Scheduled Power Outage	Rs. 50/- per hour per Consumer for the first two hours of default. Thereafter Rs. 100/- per hour per Consumer					
22	Site Visit and Intimation to the Consumer about likely time to resolve the complaint related to voltage fluctuation.	Rs. 200/- for each instance for each complaint.					
23	Complaint of Neutral	Rs. 250/- for each complaint					
	Voltage Complaint regarding Voltage	·					
24	variations at the point of commencement of supply.	Rs. 25/- for each day of default subject to maximum of Rs. 500/-					

Year : 2024-25

SoP 17: Individual Compliant where Compensation has been paid

Sr. No.	Complaint No.	Date of filing Complaint/ Automatic Compensation	Consumer No. and Name and Address of the Consumer	Nature of Complaint	Reference Standard of Performance	Amount of compensation (Rs.)	Whether Compensation paid automatically or Consumer has to approach CGRF to get compensation	Whether CGRF has upheld demand of Consumer of Compensation and if Yes, date of order of CGRF and date of compensation paid		
Dahej Lic	ence Area									
	NIL									

Year: 2024-25

SoP 18: Unauthorised Use of electricity

No. of cases booked	No. of cases where UUE is established by the Licensee	No. of cases where appeal filed by the consumer before the Appellate Authority	_	No. of cases decided by the Appellate Authority in favour of the consumer			
Dahej Licence Area							
NIL							
1							

Note: The format shall include individual consumer wise details

Year: 2024-25

SoP 019: Theft of electricity

No. of cases booked	No. of complaints filed by the Licensee in Police Station	No. of cases in which judgment delivered by the Special Court	No. of cases decided by the Special Court in favour of Licensee	No. of cases decided by the Special Court in favour of Consumer				
Dahej Licence Area								
NIL								

Note: The format shall include individual consumer wise details